






LEGEND:

SCHEDULE OF FIRE ALARM PANEL & COMPONENTS				
ITEM	SYMBOL	DESCRIPTION	MAKE	QTY.
1		CONVENTIONAL FIRE ALARM PANEL 2-ZONE, WITH 24 HOURS BATTERY BACK-UP	-	01
2		MANUAL FIRE ALARM BREAK GLASS UNIT	-	01
3		FIRE ALARM BELL"	-	01
4		OPTICAL SMOKE DETECTOR	-	04
5		"FIRE RETARDANT" CABLE (FOR WIRING TO ALL FIRE ALARM EQUIPMENT) IN 25mmØ PVC CONDUIT IN CEILING SPACE	REPUTED	LOT

NOTE :

- .THE EXISTING CONVENTIONAL FIRE ALARM PANEL 2 ZONES TO BE DEPLOYED IN THE HAZARDOUS STORE
- .THE 2 ZONE CONVENTIONAL FIRE ALARM PANEL TO BE ENCLOSED IN THE LOCKABLE WEATHERPROOF WITH A TRANSPARENT GLASS IP66 PANEL



No.	Revision	Date
<p>ENGINEERS</p> <p>DH ENGINEERING CONSULTANTS</p> <p>CONSULTING ENGINEERS AND PROJECT MANAGERS <small>P.O. BOX 37828 TEL: 221776 FAX: 226555 CELL: 096769654, 095-9113115 Email: dholmes@dhengineering.com</small></p> <p>LUSAKA ZAMBIA</p>		
<p>CLIENT</p> <p>CHEMONICS</p>		
<p>PROJECT</p> <p>PROPOSED FIRE DETECTION FOR ZAMMSA LUANSHYA REGIONAL HUB .</p>		
<p>TITLE:</p> <p>SITE PLAN - HAZARDOUS STORE</p>		
DATE	CHECKED BY:	
07 2022	A.S	
DRAWN BY	SCALE	
R.K.S	N.T.S	
DWG NO.	DH21-2022-E-02	